



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: So. Lew 22

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: So. Lew 22
Received: 09/28/2016 15:00
Reported: 11/15/2016 20:28

Analytical Testing Parameters

Client Sample ID: 11A
Lab Sample ID: J6J0110-01
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0193	0.0150	0.00100	mg/L	G	11/01/16 2015	11/02/16 1312

Analytical Testing Parameters

Client Sample ID: 11C
Lab Sample ID: J6J0110-02
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0139	0.0150	0.00100	mg/L		11/01/16 2015	11/02/16 1314

Analytical Testing Parameters

Client Sample ID: 12A
Lab Sample ID: J6J0110-03
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0165	0.0150	0.00100	mg/L	G	11/01/16 2015	11/02/16 1315



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 12B
Lab Sample ID: J6J0110-04
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00602, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1315

Analytical Testing Parameters

Client Sample ID: 13A
Lab Sample ID: J6J0110-05
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0370, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1316

Analytical Testing Parameters

Client Sample ID: 2BL
Lab Sample ID: J6J0110-06
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00295, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1317



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J6J0110-07
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0257, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1319

Analytical Testing Parameters

Client Sample ID: 9A
Lab Sample ID: J6J0110-08
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00126, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1319

Analytical Testing Parameters

Client Sample ID: 11B
Lab Sample ID: J6J0110-09
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00434, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1320



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 14
Lab Sample ID: J6J0110-10
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00353, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1322

Analytical Testing Parameters

Client Sample ID: 13B
Lab Sample ID: J6J0110-11
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0486, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1323

Analytical Testing Parameters

Client Sample ID: 15A
Lab Sample ID: J6J0110-12
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00108, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1323



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 15B
Lab Sample ID: J6J0110-13
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00154, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1324

Analytical Testing Parameters

Client Sample ID: 4
Lab Sample ID: J6J0110-14
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0330, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1325

Analytical Testing Parameters

Client Sample ID: 5
Lab Sample ID: J6J0110-15
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0310, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1325



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 6
Lab Sample ID: J6J0110-16
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00466, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1326

Analytical Testing Parameters

Client Sample ID: 7
Lab Sample ID: J6J0110-17
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0184, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1329

Analytical Testing Parameters

Client Sample ID: 8A
Lab Sample ID: J6J0110-18
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00577, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1331



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 8B
Lab Sample ID: J6J0110-19
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00970, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1332

Analytical Testing Parameters

Client Sample ID: 2AL
Lab Sample ID: J6J0110-20
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00976, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1333

Analytical Testing Parameters

Client Sample ID: 2AR
Lab Sample ID: J6J0110-21
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0314, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1333



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 90B
Lab Sample ID: J6J0110-22
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0362, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1334

Analytical Testing Parameters

Client Sample ID: 93
Lab Sample ID: J6J0110-23
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0213, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1335

Analytical Testing Parameters

Client Sample ID: 8C
Lab Sample ID: J6J0110-24
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0142, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1335



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 89
Lab Sample ID: J6J0110-25
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00609, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1336

Analytical Testing Parameters

Client Sample ID: 74
Lab Sample ID: J6J0110-26
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00694, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1337

Analytical Testing Parameters

Client Sample ID: 1
Lab Sample ID: J6J0110-27
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00752, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1340



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 72A
Lab Sample ID: J6J0110-28
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0251, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1341

Analytical Testing Parameters

Client Sample ID: 76A
Lab Sample ID: J6J0110-29
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00474, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1342

Analytical Testing Parameters

Client Sample ID: 86
Lab Sample ID: J6J0110-30
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0124, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1342



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 75
Lab Sample ID: J6J0110-31
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 06:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00832, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1343

Analytical Testing Parameters

Client Sample ID: 73
Lab Sample ID: J6J0110-32
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 06:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00886, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1344

Analytical Testing Parameters

Client Sample ID: 87
Lab Sample ID: J6J0110-33
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00590, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1344



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 81
Lab Sample ID: J6J0110-34
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0261, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1345

Analytical Testing Parameters

Client Sample ID: 91A
Lab Sample ID: J6J0110-35
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0230, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1346

Analytical Testing Parameters

Client Sample ID: 78
Lab Sample ID: J6J0110-36
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0121, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1348



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 79A
Lab Sample ID: J6J0110-37
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0174, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1350

Analytical Testing Parameters

Client Sample ID: 79B
Lab Sample ID: J6J0110-38
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00169, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1350

Analytical Testing Parameters

Client Sample ID: 46B
Lab Sample ID: J6J0110-39
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0115, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1351



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 92A
Lab Sample ID: J6J0110-40
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00863, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1352

Analytical Testing Parameters

Client Sample ID: 90A
Lab Sample ID: J6J0110-41
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0513, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1352

Analytical Testing Parameters

Client Sample ID: 82A
Lab Sample ID: J6J0110-42
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.102, 0.0150, 0.00100, mg/L, G, 11/09/16 0918, 11/09/16 1903



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 91B
Lab Sample ID: J6J0110-43
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0205, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1353

Analytical Testing Parameters

Client Sample ID: 88
Lab Sample ID: J6J0110-44
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, , 11/01/16 2015, 11/02/16 1354

Analytical Testing Parameters

Client Sample ID: 83
Lab Sample ID: J6J0110-45
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0190, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1356



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 46A
Lab Sample ID: J6J0110-46
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00212, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1356

Analytical Testing Parameters

Client Sample ID: 40A
Lab Sample ID: J6J0110-47
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0105, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1358

Analytical Testing Parameters

Client Sample ID: 40B
Lab Sample ID: J6J0110-48
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00427, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1359



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 42
Lab Sample ID: J6J0110-49
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0102, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1421

Analytical Testing Parameters

Client Sample ID: 44A
Lab Sample ID: J6J0110-50
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0106, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1422

Analytical Testing Parameters

Client Sample ID: 44B
Lab Sample ID: J6J0110-51
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0122, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1422



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 43
Lab Sample ID: J6J0110-52
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0140, 0.0150, 0.00100, mg/L, 11/01/16 2015, 11/02/16 1423

Analytical Testing Parameters

Client Sample ID: 80
Lab Sample ID: J6J0110-53
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0172, 0.0150, 0.00100, mg/L, G, 11/01/16 2015, 11/02/16 1425

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J6J0110-54
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00773, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1426



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 48GM
Lab Sample ID: J6J0110-55
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00466, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1426

Analytical Testing Parameters

Client Sample ID: 48GR
Lab Sample ID: J6J0110-56
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00281, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1427

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J6J0110-57
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00378, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1427



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 45A
Lab Sample ID: J6J0110-58
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00927, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1428

Analytical Testing Parameters

Client Sample ID: 92B
Lab Sample ID: J6J0110-59
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 07:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00867, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1429

Analytical Testing Parameters

Client Sample ID: 41A
Lab Sample ID: J6J0110-60
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1429



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 41B
Lab Sample ID: J6J0110-61
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1433

Analytical Testing Parameters

Client Sample ID: 22M
Lab Sample ID: J6J0110-62
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00699, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1433

Analytical Testing Parameters

Client Sample ID: 19A BOYS
Lab Sample ID: J6J0110-63
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0152, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1434



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 17
Lab Sample ID: J6J0110-64
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00462, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1435

Analytical Testing Parameters

Client Sample ID: 10
Lab Sample ID: J6J0110-65
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00354, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1435

Analytical Testing Parameters

Client Sample ID: 19B
Lab Sample ID: J6J0110-66
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0148, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1436



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J6J0110-67
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00741, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1437

Analytical Testing Parameters

Client Sample ID: 21
Lab Sample ID: J6J0110-68
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1437

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J6J0110-69
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00761, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1438



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 39A
Lab Sample ID: J6J0110-70
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00116, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1439

Analytical Testing Parameters

Client Sample ID: 39B
Lab Sample ID: J6J0110-71
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00964, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1442

Analytical Testing Parameters

Client Sample ID: 48BL
Lab Sample ID: J6J0110-72
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0113, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1443



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J6J0110-73
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00849, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1443

Analytical Testing Parameters

Client Sample ID: 48BR
Lab Sample ID: J6J0110-74
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00512, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1444

Analytical Testing Parameters

Client Sample ID: 48BM
Lab Sample ID: J6J0110-75
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00715, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1445



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 48GL
Lab Sample ID: J6J0110-76
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00558, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1445

Analytical Testing Parameters

Client Sample ID: 16
Lab Sample ID: J6J0110-77
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 08:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00627, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1446

Analytical Testing Parameters

Client Sample ID: 54R
Lab Sample ID: J6J0110-78
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0139, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1446



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 51R
Lab Sample ID: J6J0110-79
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00557, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1448

Analytical Testing Parameters

Client Sample ID: 51L
Lab Sample ID: J6J0110-80
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00929, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1449

Analytical Testing Parameters

Client Sample ID: 51M
Lab Sample ID: J6J0110-81
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00653, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1451



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 20
Lab Sample ID: J6J0110-82
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0179, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1452

Analytical Testing Parameters

Client Sample ID: 53
Lab Sample ID: J6J0110-83
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0178, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1452

Analytical Testing Parameters

Client Sample ID: 37
Lab Sample ID: J6J0110-84
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00330, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1453



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J6J0110-85
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1454

Analytical Testing Parameters

Client Sample ID: 62BL
Lab Sample ID: J6J0110-86
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00678, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1454

Analytical Testing Parameters

Client Sample ID: 52
Lab Sample ID: J6J0110-87
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0178, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1456



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 70WR
Lab Sample ID: J6J0110-88
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00408, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1457

Analytical Testing Parameters

Client Sample ID: 50
Lab Sample ID: J6J0110-89
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1458

Analytical Testing Parameters

Client Sample ID: 22W
Lab Sample ID: J6J0110-90
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00424, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1458



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 54M
Lab Sample ID: J6J0110-91
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0114, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1500

Analytical Testing Parameters

Client Sample ID: 54L
Lab Sample ID: J6J0110-92
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00602, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1501

Analytical Testing Parameters

Client Sample ID: 56
Lab Sample ID: J6J0110-93
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0181, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1502



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 62GR
Lab Sample ID: J6J0110-94
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00873, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1502

Analytical Testing Parameters

Client Sample ID: 55
Lab Sample ID: J6J0110-95
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0226, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1504

Analytical Testing Parameters

Client Sample ID: 62
Lab Sample ID: J6J0110-96
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0105, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1505



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 59
Lab Sample ID: J6J0110-97
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0114, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1506

Analytical Testing Parameters

Client Sample ID: 58
Lab Sample ID: J6J0110-98
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00621, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1506

Analytical Testing Parameters

Client Sample ID: 62BR
Lab Sample ID: J6J0110-99
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00557, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1507



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 60
Lab Sample ID: J6J0110-AA
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0267, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1508

Analytical Testing Parameters

Client Sample ID: 62GL
Lab Sample ID: J6J0110-AB
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0101, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1509

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J6J0110-AC
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0710, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1510



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 71GM
Lab Sample ID: J6J0110-AD
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00613, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1512

Analytical Testing Parameters

Client Sample ID: 71GL
Lab Sample ID: J6J0110-AE
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0269, 0.0150, 0.00100, mg/L, G, 11/01/16 2023, 11/02/16 1513

Analytical Testing Parameters

Client Sample ID: 71BR
Lab Sample ID: J6J0110-AF
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00513, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1513



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 71GR
Lab Sample ID: J6J0110-AG
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00849, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1520

Analytical Testing Parameters

Client Sample ID: 70ML
Lab Sample ID: J6J0110-AH
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00333, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1521

Analytical Testing Parameters

Client Sample ID: 71BL
Lab Sample ID: J6J0110-AI
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0101, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1522



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0110

Analytical Testing Parameters

Client Sample ID: 64
Lab Sample ID: J6J0110-AJ
Sample Type: Grab

Collected By: FH-Client
Collection Date: 09/23/16
Collection Time: 09:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00570, 0.0150, 0.00100, mg/L, 11/01/16 2023, 11/02/16 1522

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, Item, Yes. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice.

Project Requested Certification(s)

Table with 2 columns: Microbac Laboratories, Inc. (NY Lab ID No., Chicagoland NY Lab ID No., PA DEP ID) and New York State Department of Health / Pennsylvania Department of Environmental Protection.

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
11/15/2016 20:28

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

So. Lew 22

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckler, Oneida, BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	Date Req:				Accepted?	YES NO
Relate to DOH:	Yes					Container Material	
Email Results:	Yes					Container size(in MI)	
Fax Results:	Yes					Preservative	
						Comments/Flags	

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Type		
1 11A	9/23	8:35	FH			
2 11C		8:27				
3 12A		8:33				
4 12B		8:33				
5 13A		8:35				
6						
7						
8						

Print Name and Company	Signature	Date/Time
Sampled: Fred Hawk	<i>[Signature]</i>	9/28 9:00
Received: D. Hecker	<i>[Signature]</i>	9/28 15:00
Received:		
Received:		
Received:		
Received:		



J6J0110

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

So. Lew 22
 MNY Workorder #

Samples must be returned on ice

Client Information		Billing/Invoice:		Analyte Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckman, Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Release to DOH:	Yes	Date Req:				Container Material	
Email Results:	Yes					Container Size (in ml)	
Fax Results:	Yes					Preservative	
	rfilley@boces.com					Comments/Field Data	
	200.8 Lead						
	P						
	250						
	HNO3						
Sample Information							
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analyte Requested	Comments/Field Data
1 2 BL	9/23	8:13	FH				
2 3		8:13					
3 9A		8:35					
4 11B		8:35					
5 14		8:38					
6 13B		8:37					
7 15A		8:39					
8 15B		8:40					
Sampled:		Print Name and Company		Signature		Date/Time	
Fred Huck		Fred Huck		[Signature]		9/23 0900	
Received:		D. Blecher		[Signature]		9-28 1500	
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with that.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

So. Lew 22

Client Information		Billing/Invoice:		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckinger, Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Relocate to DOH:	Yes	Date Req:				Container Material	
Email Results:	Yes					Container Size (in ml)	
Fax Results:	Yes					Preservative	
	rfilley@boces.com / fhawck@boce.s.com					Comments/Field Data	

Sample Information			Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Initial	Type	
1	4	9/23	820	FH	
2	5		822		
3	6		825		
4	7		830		
5	8A		832		
6	8B		833		
7	ZAL		816		
8	ZAR		811		

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	Fred Hawck	<i>Fred Hawck</i>	9/28 9:00	
Received:	DB Bacheval	<i>DB Bacheval</i>	9/28 15:00	
Received:				
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with that.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

So. Lew 22
 MNY Workorder #

Samples must be returned on ice

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckinger, Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Run TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Release to DOH: Yes		Date Req:				Container Material	
Email Results: Yes	rfilley@boces.com					Container Size (In MI)	
Fax Results: Yes	rfilley@boces.com / fhayck@boces.com					Preservative	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
86	9/23	725	FH				
75		656					
73		654					
87		735					
81		713					
91A		731					
78		706					
79A		710					
Sampled: Fred Hayck		Signature: [Signature]		Date/Time: 9/23 9:00		Comments:	
Received: [Signature]		Signature: [Signature]		Date/Time: 9/28 15:00		Comments:	
Received:		Signature:		Date/Time:		Comments:	
Received:		Signature:		Date/Time:		Comments:	
Received:		Signature:		Date/Time:		Comments:	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

So. Lew 22
 MNY Workorder #

Samples must be returned on ice

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckinger, Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Relate to DOH: Yes						Container Material	
Email Results: Yes	rfilley@boces.com					Container size (In MI)	
Fax Results: Yes	ffhawck@boces.com					Preservative	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
79 B	9/23	7:10	FH				
96 B		7:51					
92 A		7:40					
90 A		7:31					
82 A		7:20					
91 B		7:31					
88		7:36					
83		7:14					
Sampled: Fred Hawck		Signature		Date/Time			
Received: D. Medchek				9/23 9:00			
Received:				9/28 15:00			
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

So. Lew 22
 MNY Workorder #

Samples must be returned on ice

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckinger, Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Release to DOH: Yes		Date Req:				Container Material	
Email Results: Yes	rfilley@boces.com / fflawck@boce.s.com					Container Size (in ml)	
Fax Results: Yes						Preservative	
						Comments/Field Data	

Sample Information				Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Matrix Type		
46A	9/23	7:51	FH			
46A		8:05				
40B		8:05				
412		8:06				
44A		8:06				
44B		8:06				
43		8:07				
80		7:12				

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	Fred Flawck		9/28 9:00	
Received:	DT Beckler		9/28 15:00	
Received:				
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

So. Lew 22
 MNY Workorder #

Samples must be returned on ice

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES			Ice:	YES NO	Container Material	YES NO
Address:	20104 NYS Route 3			Cooler:	YES NO	Container Size(In MI)	YES NO
Contact:	Watertown, NY 13601			Sample Temp:		Preparative	
Phone:	Ray Filley			Cooler Seal:	YES NO	Comments/Field Data	
Project:	315-779-7054			Pickup:	YES NO		
Quote ID:	Lead Testing			Dropoff:	C W		
Rush TAT Bur. Days:	2-5 5-7 7-10			Accepted?	YES NO		
Relate to DOT:	Yes						
Email Results:	Yes						
Fax Results:	Yes						
	rfilley@boces.com						
	fflawck@boces.com						

Sample Information			Matrix Type		Number of Containers for Analysis Requested		Comments	
Description/Location	Date	Time	Initial	Matrix	Type			
29	9/23	9:01	FH					
48 Cm		9:13		250				
48 GR		9:13		HN03				
31		9:52						
45 A		7:50						
92 B		7:41						
41 A		8:07						
41 B		8:07						

Sampled:	Free Hawk	Signature	
Received:	DP Breche	Signature	9/28 0900
Received:		Signature	9/28 1500
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

So. Lew 22

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Resking, Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Release to DOH:	Yes	Date Req:				Container Material:	
Email Results:	Yes					Container size(In Mt)	
Fax Results:	Yes					Preservative	
	rfilley@boCES.com / fhauck@boCES.com					Comments/Field Data	

Sample Information				Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Matrix Type		
22 m	9/23	9:15	FH			
19A Rays		8:45				
17		8:42				
10		8:50				
19B		8:45				
32		9:00				
21		8:51				
30		9:01				

Sampled:	Print Name and Company	Signature	Date/Time
Received:	Fred Hauck	<i>Fred Hauck</i>	9/28 9:00
Received:	D Brechele	<i>D Brechele</i>	9/28 15:00
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

So. Lew 22

Client Information		Billing/Invoices		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckler, Oneida BOCES			Ice:	YES NO	YES NO	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	YES NO	YES NO
Contact:	Ray Filley			Sample Temp:			
Phone:	315-779-7054			Cooler Seal:	YES NO	YES NO	YES NO
Project:	Lead Testing			Pickup:	YES NO	YES NO	YES NO
Quote ID:				Dropoff:	C W	C W	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:		Accepted?	YES NO	YES NO	YES NO
Release to DOH:	Yes	Date Req:		Container Material:			
Email Results:	Yes			Container Size (in MI):			
Fax Results:	Yes			Preservative:			
				Comments/Field Data			

Sample Information				Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Matrix	Type	
39A	9/23	9:08	FH	P	200.8 Lead	
39B		9:06		250		
48 BL		9:16		HNO3		
35		8:50				
48 BL		9:12				
48 BM		9:11				
48 CL		9:12				
16a		8:42				

Sampled:	Print Name and Company	Signature	Date/Time
39A	Fred Huck	<i>[Signature]</i>	9/28 9:00
39B	DB Becker	<i>[Signature]</i>	9-28 15:00
48 BL			
35			
48 BL			
48 BM			
48 CL			
16a			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

So. Lewis 22

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES					Ice:	YES (NO) <input checked="" type="checkbox"/>
Address:	20104 NYS Route 3					Cooler:	YES (NO) <input checked="" type="checkbox"/>
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES (NO) <input checked="" type="checkbox"/>
Project:	315-779-7054					Pickup:	YES (NO) <input checked="" type="checkbox"/>
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES (NO) <input checked="" type="checkbox"/>
Relate to DOH: Yes		Date Req:				Container Material	
Email Results: Yes						Container size (in MI)	
Fax Results: Yes						Preservative	
						Comments/Field Data	

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Type		
54 R	9/23	9:23	FH			
51 R		9:20				
51 L		9:20				
51 M		9:20				
20		9:50				
53		9:25				
37		9:05				
38		9:07				

Sampled:	Print Name and Company	Signature	Date/Time
54 R	Fred Hack	<i>[Signature]</i>	9/28 9:00
51 R	DR Beche	<i>[Signature]</i>	9-28 1500
51 L			
51 M			
20			
53			
37			
38			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

So. Lew 22

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Relates to DOH: Yes						Container Material	
Email Results: Yes	filley@boces.com					Container size (in ML)	
Fax Results: Yes	fflawck@boces.com					Preservative	
						Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 602 02	9/23	9:35	FH				
2 52		9:22					
3 70 02		9:43					
4 50		9:17					
5 220		9:15					
6 54 M		9:23					
7 54L		9:23					
8 56		9:24					
Sampled: Fred HAWCK				Signature			
Received: B. Becker				Date/Time			
Received:				9/28/00			
Received:				9/28/00			
Received:							
Received:							
Received:							
Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.							

Microbac Laboratories, Inc. CHAIN OF CUSTODY

So. Lew 22

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush TAT Bur. Days:	2-5 5-7 7-10	Date Req:	
Release to DOH: Yes			
Email Results: Yes	filley@booces.com		
Fax Results: Yes	fshawck@booces.com		

Sample Information				Matrix Type	
Description/Location	Date	Time	Initial	Matrix	Type
1 602 GR	9/23	9:30	FH	250	HM03
2 55		9:22			
3 62		9:38			
4 59		9:35			
5 58		9:30			
6 602 BE		9:35			
7 600		9:35			
8 602 CL		9:36			

Receiving Info (Lab Use Only)		Analytix Requested		Number of Containers for Analysis Requested		Comments/Field Data	
Ice:	YES NO						
Cooler:	YES NO						
Sample Temp:							
Cooler Seal:	YES NO						
Pickup:	YES NO						
Dropoff:	C W						
Accepted?	YES NO						
Container Material							
Container Size(In MI)							
Preservative							

Signature	Date/Time	Comments
<i>Fred Hawck</i>	9/28 9:00	
<i>DR Becker</i>	9/28 15:00	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

So. Lew 22

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	rfilley@boces.com					Container Size (In MI)	
Fax Results: Yes	ffhauk@boces.com					Preparative	
						Comments/Field Data	

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments	
Description/Location	Date	Time	Initial	Type			
34	9/23	9:05	FH				
71 QM		9:41					
71 GAL		9:40					
71 BR		9:42					
71 GR		9:41					
20 ML		9:43					
71 BL		9:42					
Co4		9:36					

Signature		Defer/Time	
Print Name and Company	Signature		
Fred Hauk	<i>[Signature]</i>	9/23	9:00
D. Echeverre	<i>[Signature]</i>	9-28	1:00
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.